Authentisign ID: E08C5E42-C26B-F011-8DCA-00224822F75A

JACKSON-MADISON COUNTY HEALTH DEPARTMENT
PERMIT FOR CONSTRUCTION OF SUBSURFACE SEWAGE DISPOSAL SYSTEM

Issued to: Jean Perry
Owner, Developer, Contractor, Installer, Etc.

Location: 176 Old Denmark Rd

Installation:
To be constructed by: Larry Davenport
( ) 1. New Installation
(X) 2. Repair to Existing System

Establishment:
( ) 1. Residential: # Bedrooms
( ) 2. Other: (specify)
Gal/Day

Evaluation Based Upon:
( ) 1. Soil typing by Soil Scientist
( ) 2. Soil Percolation Test
( ) 3. Environmental Specialist

Estimated Absorption Rate:
Minutes per inch

Conventional Systems:
Type of System: (X) 1. Standard
( ) 2. Alternating
( ) 3. Chapter
( ) 4. Other

Permit Requirements Based Upon:
( ) Soil Texture/Structure
( ) Soil Depth
( ) Soil Drainage
( ) Presence of Restrictive Layers
( ) Position

Alternative Systems:
( ) 1. Low Pressure Pipe
( ) 2. Mound
( ) 3. Lagoon
( ) 4. Large diameter graveless pipe
( ) 5. Other
See attached design package

This system shall consist of a two compartment septic tank holding existing 1000 gallon gallons, with 150 linear feet in 3 trenches, 36 inches wide and 24-32 inches deep.

Also required:
( ) 1. Curtain Drain
( ) 2. Flow Diversion Valve
( ) 3. Sewage Pump
( ) 4. Other

The recipient of this permit agrees to construct or have constructed the above described system in accordance with Jackson-Madison County Board of Health Regulations To Govern Subsurface Sewage Disposal Systems. If any part of the system is covered before being inspected and approved, it shall be uncovered by the recipient of the permit at the direction of personnel of the Jackson-Madison County Health Department. Any cutting, filling or alterations of the soil conditions on the aforementioned property after this day may render this approval null and void.

x Larry Davenport (Signature of Recipient) Date 6-10-2002

Issued at Lexington Tennessee, in Madison County

By Jim Howell, Sr. Sanitarian (Name and Title) Date 6-10-2002 (Date of Issue)

Notes NOT TO SCALE



Inspected by: Jim Howell
Local Health Authority

Date: 6-10-2002

Construction Approval (X) 1. Yes ( ) 2. No

Original-File
Copy-Owner