



Stanfield Air Systems  
 1130 Mitchell Bridge Rd.  
 Athens, Georgia 30606  
 (706) 549-4767  
 www.stanfieldair.com

**BILL TO**  
 Ed Pfeiffer  
 127 Bordeaux Lane  
 Athens, GA 30605 USA

<b>INVOICE</b> 100228017	<b>INVOICE DATE</b> May 20, 2026
-----------------------------	-------------------------------------

**JOB ADDRESS**  
 Ed Pfeiffer  
 127 Bordeaux Lane  
 Athens, GA 30605 USA

**Completed Date:**  
**Payment Term:** Due Upon Receipt

**DESCRIPTION OF WORK**

On arrival, I found the main system was not cooling because it had lost all of it's refrigerant. The valve core on the suction side of the service valves had a bad gasket. I replaced the valve core and recharged the system with 11 lbs of 410A refrigerant. It's back to working properly again. Since we had been out for service mid April and failed to notice the valve was leaking, I split the cost of refrigerant with you and waived the service charge.

Thank you! -Sean

TASK	DESCRIPTION	QTY	STANDARD PRICE	PRICE	TOTAL
RRL-160	Add 1 lb R-410A Refrigerant B0.76	5.00	\$168.00	\$142.80	\$714.00

PAID ON	TYPE	MEMO	AMOUNT
5/20/2026	Check		\$714.00

MEMBER SAVINGS	\$126.00
<b>SUB-TOTAL</b>	<b>\$714.00</b>
<b>TOTAL DUE</b>	<b>\$714.00</b>
<b>PAYMENT</b>	<b>\$714.00</b>
<b>BALANCE DUE</b>	<b>\$0.00</b>

Thank you for choosing Stanfield Air Systems  
**CUSTOMER AUTHORIZATION**

**LENNOX**  
DALLAS, TEXAS

ASSEMBLED  
IN THE USA

M/N XP16-048-230-08

S/N 5818J02867

CONTAINS HFC-410A DESIGN PRESSURE

FACTORY CHARGE HI 448 PSIG

10 LBS 9 OZS LO 236 PSIG

ELECTRICAL RATING NOMINAL VOLTS 230

1 PH 60 HZ MIN 208 MAX 253

COMPRESSOR FAN MOTOR

PH 1 PH 1

BLA 1 PH 1.8

LBA 1 PH 1/3

MAX FUSE ON CMT. SWL  
FUSE/TERMINAL CIRCUIT  
(RATED 48)

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

LENNOX

5:52



4G+ 82



